



Certificate

This is to certify that Richwise (Australia) Pty Ltd

ABN 49 094 307 918

Head Office Address Suite 19, 1253 Nepean Highway

Cheltenham, Victoria, 3192

Australia

Holds Certificate Number BMP 638334

Is authorised to use the BSI registered Benchmark Product Certification Trademark, on products identified in the Product Certification Schedule that is attached to this Product Certification Certificate. Such products have been Type Tested and are manufactured under the Product Certification Requirements monitored by BSI to ensure that the manufacturing process has the capability to consistently produce products in compliance with and are Certified to:

AS6669:2007 Plywood - Formply

For and on behalf of BSI

Marc Barnes, Managing Director, BSI Group ANZ Pty Ltd

Originally registered Latest issue Expiry date 31/07/2015 01/09/2015 30/07/2020





...making excellence a habit.





Schedule

This schedule supports the Product

Certification Certificate for

Richwise (Australia) Pty Ltd

ABN

49 094 307 918

Head Office Address

Suite 19, 1253 Nepean Highway Cheltenham, Victoria, 3192

Australia

Holds Certificate Number

BMP 638334

Standard

AS6669:2007 Plywood - Formply

Issue date

01/09/2015

Model	BSI Review Date	Description				
V-RWFORM	01/09/2015	Formply 17.5-9-13, Class 2 A Bond, Veneer Grade BB, E _o F22 (I 242 – Z 27.2 / I 206.2 – Z 25.6)				
		Plywood Face Grain Direction	Plywood Type	Bending fpb	Panel Shear fps	Modulus of Elasticity
		Parallel	17.5mm 13-ply Formply	110.43 (F34)	10.98 (F34)	19.40 (F27)
		Perpendicular	17.5mm 13-ply Formply	77.49 (F27)	11.04 <i>(F34)</i>	18.21 (F22)



BMP 638334 01/09/2015 Page 2 of 2

...making excellence a habit.